

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3776-0139:127

Page 1 of 1

CATEGORY: Electric Door Strikes/Power Supply

LISTEE: Von Duprin, 2720 Tobey Dr., Indianapolis IN 46219
Contact: Roger Vitt *(317) 715-4420 Fax (317) 715-4473

DESIGN: Model 5100 burglary resistant electric door strike. The unit is an assembly consisting of an electrically operated coil springs, and internal wiring, all secured in a die cast alloy enclosure. It is intended for installation in a door frame and is designed for use with most cylindrical, mortise and unit type locks. These devices are intended to be used with electric locking mechanisms. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12 or 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as electric strike for use with separately listed mechanical or other electric locking devices.

*Rev. 06-13-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 13, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager